

Unit 6,The Cedar Business Centre Avon Road, Cannock, Staffs WS11 1QJ Tel: +44 (0)1543 501 600 Fax: +44 (0)1543 501 601

## **Manufacturer's Declaration of Conformity**

We declare that the following products:-

# AMG202/AT AMG203/AT, AMG204/AT, AMG205/AT, AMG206/AT, AMG207/AT

have been successfully tested to the following:-

### **Evidence of Fire Test Compliance**

- Fire Tested to EN1634-1 on Timber Doors for 30 mins. and 1 Hour Exova Warrington Fire Test Report No. 341521 dated 29<sup>th</sup> August 2014
- 2mm thick Interdens intumescent should be wrapped around the studs within the door leaf to comply with EN1634-1

#### **Evidence of Performance Test**

- Certified and tested to TS010:2016 WTE Report No. 17-002 Dated 25<sup>th</sup> January 2017
- Classification Code
- 3 7 B 1 3 2 2 A
- Durability Grade 7 (200,000 cycles)
- Holding force without Z&L Bracket Grade 2 (Tested Holding Force 2650N / 595lbs)
- Salt Spray Tested Grade 3 (96 hours)
- Safety Grade 1 (Safety Bolts)
- Type of Device Grade A (Face to face fixed Electro-Magnetic Lock)

#### EMC Directive 89 / 336 / EEC

- Tested by Matrix Test Laboratory, 2F, No. 146 Jian Yi Road, Chung-Ho Dist., New Taipei City, Taiwan R.O.C.
- Certification No. R12041303E-B01 dated 18<sup>th</sup> April 2012
- EN61000-6-3:2007 + A1:2011 (Emissions)
- EN61000-6-1:2007 (Immunity) IEC61000-4-2:2008, IEC61000-4-3:2006+A1:2007+A2:2010 IEC61000-4-8:2009

Ko lally

Technical Director Signed on behalf of Securefast plc

Date: 27<sup>th</sup> January 2017