

## Manufacturer's Declaration of Conformity

We declare that the following products:-

**AMG202/UM AMG203/UM, AMG204/UM, AMG205/UM,  
AMG206/UM, AMG207/UM**

have been successfully tested to the following:-

### Evidence of Fire Test Compliance

- Fire Tested to EN1634-1 on Timber Doors for 30 mins. and 1 Hour – Exova Warrington Fire Test Report No. 341521 dated 29<sup>th</sup> August 2014
- 2mm thick Interdens intumescent should be wrapped around the studs within the door leaf to comply with EN1634-1

### Evidence of Performance Test

- Certified and tested to TS010:2016 – WTE Report No. 17-002 Dated 25<sup>th</sup> January 2017
- Classification Code 

3	7	B	1	3	2	0	A
---	---	---	---	---	---	---	---
- Durability – Grade 7 (200,000 cycles)
- Holding force without Z&L Bracket – Grade 2 (Tested Holding Force – 2650N / 595lbs)
- Salt Spray Tested – Grade 3 (96 hours)
- Safety – Grade 1 (Safety Bolts)
- Type of Device – Grade A (Face to face fixed Electro-Magnetic Lock)

### EMC Directive 89 / 336 / EEC

- Tested by Matrix Test Laboratory, 2F, No. 146 Jian Yi Road, Chung-Ho Dist., New Taipei City, Taiwan R.O.C.
- Certification No. R12041303E-B01 dated 18<sup>th</sup> April 2012
- EN61000-6-3:2007 + A1:2011 (Emissions)
- EN61000-6-1:2007 (Immunity)  
IEC61000-4-2:2008, IEC61000-4-3:2006+A1:2007+A2:2010  
IEC61000-4-8:2009



Technical Director  
Signed on behalf of Securefast plc

Date : 27<sup>th</sup> January 2017