

Manufacturer's Declaration of Conformity

We declare that the following product:-

**ASL941B, ASL951B & ASL951BW
Be-Tech / Smartlock Locks**

have been successfully tested

Evidence of Fire Test Compliance

- Fire Tested to EN1634-1 on Timber Doors for 1 Hour by Intertek Testing Services Limited, Shanghai (*Guardian RFID Elegant –G2, Guardian RFID Elegant Li – G3*)
- Fire Test Report No. 141222001SHJ-BP-1 dated 23rd January 2015
- 2mm thick Therm-A-Srtip intumescent strips wrapped around the lock case


Electrical Lock Test

- Tested to EN14846 by Intertek Testing Services Limited, Guangdong
- Test Report No. 131014059GZU-001 dated 21st January 2014
- Classification Code

3	S	5	D	0	J	3	1	2
---	---	---	---	---	---	---	---	---

Performance Test

- Self-closing Ability – Grade 5 – Up to 200 kg door mass, 25N maximum closing
- Durability of Latch – 200,000 test cycles with 50N load on the latch bolt
- Suitability for use on fire/smoke doors – Grade D Suitable for FD60 Timber Doors
- Dangerous Substances - The materials in this product shall not contain or release any dangerous substance in excess of the maximum levels specified in the European material standards or any national regulations.



Technical Director
Signed on behalf of Securefast plc

Date : 1st July 2016