

## Manufacturer's Declaration of Conformity

We declare that the following product:-

**ASL941B, ASL951B, ASL951BW & ASL951BI  
Be-Tech / Smartlock Locks**

have been successfully tested

### Evidence of Fire Test Compliance

- Fire Tested to EN1634-1:2014 on Single Action Timber Doors for 1 Hour by Warrington Exova Fire
- Fire Test Report No. 386552 dated 24<sup>th</sup> October 2017
- 2mm thick interdens intumescent wrapped around the lock case (and Battery Pack Case)


### Electrical Lock Test (ASL941B, ASL951B & ASL951BW)

- Tested to EN14846:2008 by Intertek Testing Services Limited, Guangdong
- Test Report No. 131014059GZU-001 dated 21<sup>st</sup> January 2014
- Classification Code

3	S	5	D	0	J	3	1	2
---	---	---	---	---	---	---	---	---

### Performance Test (ASL941B, ASL951B & ASL951BW)

- Self-closing Ability – Grade 5 – Up to 200 kg door mass, 25N maximum closing
- Durability of Latch – 200,000 test cycles with 50N load on the latch bolt
- Suitability for use on fire/smoke doors – Grade D Suitable for FD60 Timber Doors
- Dangerous Substances - The materials in this product shall not contain or release any dangerous substance in excess of the maximum levels specified in the European material standards or any national regulations.



Technical Director  
Signed on behalf of Securefast plc

Date : 1<sup>st</sup> November 2017